



**BUREAU
VERITAS**

Certificate of compliance

Applicant: Q3 Energie GmbH & Co. KG
Innovapark 20
87600 Kaufbeuren
Germany

Product: Switch Disconnecter

Model: Q3 QFirePV-HV Standard
Q3 QFirePV-HV BIG

Ratings: DC voltage range [V] up to 1500
DC current [A] 15

Use in accordance with regulations:

The switch disconnectors are tested according to the IEC 60947-3:2020 in conjunction with IEC 60947-1:2020.

Applied rules and standards:

IEC 60947-3:2020

Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

* environmental tests were excluded – see test report for further details

At the time of issue of this certificate, the representative product listed above corresponds to the stated rules and standards.

Report number: 22TH0526-IEC60947-3_0

Certification program: NSOP-0032-DEU-ZE-V01

Certificate number: U23-0184

Date of issue:

2023-03-07

Certification body



Georg Lortz

Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH

