

Certificate of compliance

Applicant: Q3 Energie GmbH & Co. KG
Moosmangstr. 8
87600 Kaufbeuren
Germany

Product: Switch Disconnecter

Models: Q3 QFirePV-HV Standard
Q3 QFirePV-HV BIG

The certificate refers to the stated model(s) which passed the tests according to the applicable standard(s):

Applied rules and standards:

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

*** environmental tests were excluded – see test report for further details**

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 25TH0209-IEC60947-3_2

Certificate number: U25-0913

Certification Program:

NSOP-0038-DEU-ZE-V02

Date of issue:

2025-10-02

Certification body

Accreditation



Domenik Koll
Head of Energy Systems Germany



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.

Type Approval and declaration of compliance with the requirements of IEC 60947-3:2020

Manufacturer / applicant	Q3 Energie GmbH & Co. KG Moosmangstr. 8 87600 Kaufbeuren Germany			
Product type	Switch Disconnecter			
	Q3 QFirePV-HV Standard	Q3 QFirePV-HV Big	--	--
Input (DC)				
DC voltage range [V]	1500	1500	--	--
Max. DC current [A]	20	20	--	--